

**Ref:** MIAL/AO-AOS/REC/47/7549

**Date:** 05/12/2023

To,  
The Deputy Chief Engineer  
Building Proposal (Special Cell),  
Gr. Floor, Municipal Training Centre,  
Raheja Vihar Complex, Chandivali Farm Road,  
Andheri (E), Mumbai 400072.

**Sub: Proposed sale building on land bearing CTS No. 833 (Pt), of village Ambivali known as 'Andheri Printing Press' at Andheri (West), Mumbai.**

**Ref: 1) Building Proposal File No. CHE/643/BP (SPL CELL)/AKW/337-AAI/1/New.  
2) AAI NOC No: JUHU/WEST/B/120418/353210; Date: 03/01/2019.**

Dear Sir,

This is in reference to MCGM online request for joint inspection on AutoDCR, dated 03<sup>rd</sup> July 2023 on above mentioned subject.


Joint site inspection of the building under reference was carried out by MIAL representative on 08<sup>th</sup> November 2023 in presence of Mr. Rakesh Tiwari (Engineer – M/s Hubtown Ltd). Please find attached picture of the building (Wing A) which was verified and the top elevation (LMR + Solar Panel) of the building was measured to be 92.80 m AMSL and Antenna top was measured to be 94.18 m AMSL. The NOC issued by AAI for this building is for 94.27 m AMSL.

The above is for your information and further necessary action please.

Thanking you,

Yours sincerely,

For **Mumbai International Airport Ltd.**

  
**Manoj Joshi**

Sr. Manager- Airport Operation Services

**Encl:** As Above.

**Mumbai International Airport Limited**

Chhatrapati Shivaji Maharaj International Airport  
1st Floor, Terminal 1B, Santacruz (E),  
Mumbai 400 099,  
Maharashtra, India  
CIN: U45200MH2006PLC160164

Tel +91 22 6685 0900 / 6685 0901  
csmia.adaniairports.com