

Office of the Superintending Engineer, Nashik Circle, 1<sup>st</sup> Floor, Vidyut Bhavan, Bitco Chowk,  
Nashikroad, E-Mail: [senskurban@mahadiscom.in](mailto:senskurban@mahadiscom.in)

SE/NSKC/HT//No. **1033**

DATE: **21 FEB 2023**

To,  
M/S Kalantri Brothers (P) Ltd.  
D-9, Sinnar Co- Op Ind. Estate,  
Tal- Sinnar, Dist.-Nashik  
(Con No-075949006000).

**Sub:** - Load sanction for additional power supply to the extent of Contract Demand 190 kVA & Connected Load 300 kW [Totaling to CL: 1530 kW, CD: 990 kVA] on existing 11 kV voltage level to your unit at above mentioned address.

Ref.:- 1) Consumer's application Dtd. 17.01.2023.

Dear Sir,

Please refer your application mentioned above [ref.1], wherein you have requested for additional power supply to the extent of Contract Demand 190 kVA & Connected Load 300 kW [Totaling to CL: 1530 kW, CD: 990 kVA] on existing 11 kV voltage level to your unit at above mentioned address.

In exercise of the powers delegated to company as per Electricity Act 2003, we are pleased to Sanction additional power supply to the extent of Contract demand 190 kVA Contract Demand & Connected Load 300 kW [Totaling to CL: 1530 kW, CD: 990 kVA]. The load sanctioned is as follows:

Type	Connected Load (kW)	Contract Demand (kVA)	Purpose of supply/Tariff category
Existing Load	1230 kW	800 kVA	HT-IA
Additional Load	300 kW	190 kVA	
<b>Total</b>	<b>1530 kW</b>	<b>990 kVA</b>	

The Competent Authority has accorded approval for the sanction of power supply as above subject to the following conditions and shall be released after compliance of the said conditions, wherever necessary.

**1) General Condition:**

a) You shall pay the Service Connection Charges, Additional Security Deposit etc. as may be payable in accordance with existing provisions, prior to release of the additional load.

- b) All statutory clearances/ approval as may be necessary shall be obtained by you from different concerned Authorities, including the Chief Engineer (Electrical), P.W. Department, and Government of Maharashtra before release of new/ additional load.
- c) You shall also abide to pay any other charges as may be leviable for this sanction as may be decided by the Competent Quasi Judicial or any other Statutory Authority.
- d) Any increase or any additional expenditure if any, for any reason will be borne totally by you (consumer).
- e) All the statutory permission, NOC etc. will have to be arranged by you (Consumer) prior to release of this new/ additional load.
- f) You have to pay all outstanding dues/arrears of MSEDCL regarding existing HT connection before release of load enhancement.
- g) You have to pay the all dues of MSEDCL.

**You will have to give an undertaking/ affidavit on Rs. 200/- stamp paper for the above conditions before release of power supply.**

## 2) VALIDITY:

The sanction as above shall be valid for a period of Six months from the date of issue of this letter. You shall ensure to make necessary payments within one month period and should also make all other arrangement, to receive power within the validity period.

You will have to avail the supply within three months on the intimation about Company's readiness to give power supply to you, failing which you shall be liable to pay charges as per rule. The Company reserves the right to revalidate the power sanction subject to the conditions prevailing at the time of revalidation.

**3) PAYMENTS:** The various payments, as follows will have to be made by you.

S.N.	Particulars	Amount (Rs.)
1	Service connection charges (1.3% Normative Charges)	0/-
2	Security Deposit [Additional]	124077/-
3	Agreement Charges	200/-
4	Application processing & Registration charges	2500/-
5	GST	450/-
	<b>TOTAL</b>	<b>127727/-</b>

Please note that the payment against above shall be payable by you by way of DD of the Nationalized Bank, in the name of "MSEDCL, Urban Circle Nashik" payable at **NASHIK** within **ONE month**.

**4) SUPPLY VOLTAGE:** This additional load 300 kW Connected Load with 190 kVA Contract Demand (Totaling to CL: 1530 kW, CD: 990 kVA) Demand along with existing load will be supplied on existing 11 KV Voltage level.

5) **INSTALLATION:** The installation/drawing arrangement for required power supply shall be subject to the approval of concerned Electrical Inspector, Public Works Department, and Government of Maharashtra.

6) **SUBMISSION OF DOCUMENTS:** You shall have to submit following permissions / no Objection certificates/ other documents (as per applicability) before release of supply:

[As applicable from following]

- i) Clearance / NOC from MIDC.
- ii) NOC / Consent of MPCB
- iii) NOC from Environment Department, Government of Maharashtra.
- iv) Power of Attorney by way of a Resolution passed by all directors in original.
- v) Manufacturer's test certificates of equipments.
- vi) Test report of Electrical Contractors, along with the List of Machinery installed.
- vii) Permission from the concerned Electrical Inspector, Government of Maharashtra.
- viii) SSI Certificate for your company.
- ix) Any such other documents/Certificate/ Permission as may be directed by Chief Engineer (Nashik zone), MSEDCL, Nashik / S.E. (Urban circle), MSEDCL, Nashik

7) **METERING:** The metering should be according to the specifications as may be provided by the MSEDCL. The details of specification for main & Check metering are as below:-

**CTR: I/D Type 11 kV, 50/5 A, 0.5S, 10 VA, 1C, 1R, (Existing)**

**PTR: I/D Type 11 kV/110V, 0.5, 50VA, (Existing)**

**T/F. Capacity: 1X1600 kVA.**

You will have to provide & maintain proper space for the MSEDCL's line terminal structure as well as suitable room indicated by us on the approved drawing to accommodate Metering equipment at your cost.

8) **POWER FACTOR:** You shall maintain the power factor of your load within the limits as prescribed by the MSEDCL in conditions of supply, as may be applicable from time to time and you shall be liable for penalty for violation of the said provisions in accordance with the provisions of tariff as may be determined by MERC.

9) **HARMONICS CONTROL:** You shall ensure that total harmonics generated & injected in MSEDCL/ MSEDCL system by your load shall not be more than 3% & individual harmonics shall not be more than 1%. Any default on your part shall be corrected immediately. You will have to submit the harmonics analysis report within 3 (three) months from the date of release of additional load.

10) **VOLTAGE VARIATION CONTROL:** You shall provide necessary static 'VAR SOURCES' of fast responses to avoid voltage flickering due to your load and shall maintain voltage variation within +/- 1%.

11) **AGREEMENT:** You will have to enter into agreement with MSEDCL.

12) **CONDITION OF SUPPLY AND TARIFF:** The power supply shall be governed by the prevailing provisions of the MSEDCL's Conditions of supply & prevailing tariff as may be applicable in this regard and shall further be subject to such other provisions as may be prescribed by the MSEDCL from time to time.

**TARIFF: Applicable tariff is HT- IA for kVAh units & kVA demand.**

- 13) **G-7 FORM:** You shall maintain necessary information regarding energy consumption, Maximum Demand recorded etc on a day to day basis in the format as prescribed by the MSEDCL and shall produce the same on demand /shall handover to every month to authorized representative of the MSEDCL at the time of meter reading.
- 14) **POWER RESTRICTION:** The power supply shall be governed by the load restrictions orders as may be prescribed by MERC/ Government of Maharashtra from time to time. You shall also observe & follow the staggering Holiday/ Load Shedding day as informed to you, which is at present **SATURDAY** for Nashik district.
- 15) **ACCEPTANCE:** You shall submit your acceptance in writing to the above terms & conditions of power supply and acceptance letter, to this office. In case of any doubt/difficulty or if any clarification is required, you may contact to this office on any working day during working hours.
- You are requested to note the requirements /formalities carefully & arrange to comply deficiencies, if any, before making payment in your own interest so as to avoid any inconvenience/ delay at the time of release of power supply to you & ensure prompt payment to enable MSEDCL to proceed further.

Thanking You,

**(D. H. Padalkar)**  
**SUPERINTENDING ENGINEER**  
**M.S.E.D.C.L. NASHIK CIRCLE**

**Copy to:**

- 1) The Executive Engineer, MSEDCL, Nashik Rural Division, Nashik.
- 2) The Executive Engineer, MSEDCL, Testing Division, Nashik.
- 3) The Sr. Manager (F&A), Nashik Circle.
- 4) Dy. Exe. Engineer, Sinnar-I, Sub-Division.